

ELCTRICAL EQUIPMENT TESTING (PAT)

Certificate Reference

53042

CLIENT DETAILS

www.malwilliams.com

DATE

08/11/23

DETAILS OF THE CONTRACTOR RESPONSIBLE FOR THE TESTING

Registration Number

58852613

Trading Title

Mal Williams

Address

Oak Tree Cottage, Whartons Lane, SO407EF

For the inspection and testing of the electrical equipment

Name

Mal Williams

Position

Test Engineer

Signature

Mal Williams

Test Equipment

Metrel MI3311

Serial Number

10230777

Retest Date:

08/11/2024

Item / Description	Class	Visual	Earth	Insulation	Repair
001 230v Extension Lead	Class 1	Pass	0.04 OHMS	<20 MOHMS	
002 230v Extension Lead	Class 1	Pass	0.05 OHMS	<20 MOHMS	
003 230v Extension Lead	Class 1	Pass	0.05 OHMS	<20 MOHMS	
003 230v Extension Lead	Class 1	Pass	0.05 OHMS	<20 MOHMS	
004 230v IEC Lead	Class 1	Pass	0.02 OHMS	<20 MOHMS	
005 230v IEC Lead	Class 1	Pass	0.05 OHMS	<20 MOHMS	
006 230v IEC Lead	Class 1	Pass	0.03 OHMS	<20 MOHMS	
007 230v IEC Lead	Class 1	Pass	0.05 OHMS	<20 MOHMS	
008 230v IEC Lead	Class 1	Pass	0.05 OHMS	<20 MOHMS	
009 230v IEC Lead	Class 1	Pass	0.02 OHMS	<20 MOHMS	
010 230v IEC Lead	Class 1	Pass	0.05 OHMS	<20 MOHMS	
011 230v IEC Lead	Class 1	Pass	0.05 OHMS	<20 MOHMS	
012 230v IEC Lead	Class 1	Pass	0.05 OHMS	<20 MOHMS	
013 230v IEC Lead	Class 1	Pass	0.05 OHMS	<20 MOHMS	
014 N/A					
015 Amp	Class 1	Pass	0.06 OHMS	<20 MOHMS	
016 Audio	Class 1	Pass	0.05 OHMS	<20 MOHMS	
017 Lighting	Class 1	Pass	0.05 OHMS	<20 MOHMS	
018 Lighting	Class 1	Pass	0.02 OHMS	<20 MOHMS	
019 Lighting	Class 1	Pass	0.05 OHMS	<20 MOHMS	
020 Lighting	Class 1	Pass	0.05 OHMS	<20 MOHMS	
021 Lighting	Class 1	Pass	0.02 OHMS	<20 MOHMS	
022 Lighting	Class 1	Pass	0.05 OHMS	<20 MOHMS	
023 Lighting	Class 1	Pass	0.05 OHMS	<20 MOHMS	
024 Lighting	Class 1	Pass	0.05 OHMS	<20 MOHMS	
025 Lighting	Class 1	Pass	0.05 OHMS	<20 MOHMS	
026 Lighting	Class 1	Pass	0.04 OHMS	<20 MOHMS	
027 Lighting	Class 1	Pass	0.05 OHMS	<20 MOHMS	
028 Lighting	Class 1	Pass	0.05 OHMS	<20 MOHMS	
029 Lighting	Class 1	Pass	0.04 OHMS	<20 MOHMS	
030 Lighting	Class 1	Pass	0.05 OHMS	<20 MOHMS	
031 Lighting	Class 1	Pass	0.05 OHMS	<20 MOHMS	
032 Lighting	Class 1	Pass	0.02 OHMS	<20 MOHMS	